



कार्यालय नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर।

पत्रांक:-1473/D/LWA/NSA

दिनांक:-06/02/2021

प्रमाण पत्र

प्रमाणित किया जाता है की सफाई एवं खाद्य निरीक्षक/केमिस्ट स्वास्थ्य विभाग द्वारा दिनांक 30.01.2021 को दिल्ली पब्लिक स्कूल, बर्रा, कानपुर नगर का निरीक्षण किया गया तथा पानी का सैम्पल लिया गया जिसमें पेयजल की गुणवत्ता पेययोग्य एवं विद्यालय में सेनेटरी एवं हाइजेनिक स्थितियां हैल्थ मैनुअल के अनुरूप सही पायी गयी है।

नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर
ALKA SINGH
(Chemist)
Nagar Nigam Kanpur

KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the Delhi Public School BARRA, Kanpur

Sample taken from	Submersible
Date of sample Drawn	30/01/2021
Date of analysis	30/01/2021
Physical Character	Transparent
P. H. Value	8.6
Free Ammonia Parts per 1000000	N/A
Albuminoid Ammonia Part per 1000000	N/A
Oxygen absorbed from pot. Permagnate in three hours at 37° C	0.4
Chloride Part per 1000000	50.0
Nitrates Parts per 1000000	Nil
Nitrates Parts per 1000000	Nil
Total solid part per 100000	810.0
Fixed solid Parts per 1000000	640.0
Volatils solid Parts per 100000	170.0
Appearance on ignition	No Charring
Total hardness Parts per 1000000	320.0
Permanent hardness Parts per 1000000	148.0
Temporary hardness Parts per 1000000	180.0

K.N.N. PRESS

Remarks : Potable

No. 214/SO/14/hw dated 06/02/2021

Copy forwarded for favour or information to

1) Delhi Public School Barra
Kanpur

2) N.S.A. Nagar Nigam Kanpur

Nagar Swasthya Adhikari
Nagar Nigam Kanpur
नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर

Alka Singh
ALKA SINGH
(Chemist)
Nagar Nigam Kanpur

D.No. 214/SWA/chem 06/02/202



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from DELHI PUBLIC SCHOOL, SARRA, KANPUR

Name & designation of the person collecting samples..... Alka Singh - Chemist (K-10)

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count			Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARK
		at 37.c in 48 hours	at room temp- ratur in 72 hours	Quantity of water put in each tube No of tubes put up	50ML. 1	10 ML. 5			

30/01/2021 'Submersible' 34 50 — NIL 2 2 2 gen NIL

Satisfactory

Remarks: Chlorination is necessary / f.c must be 0.2 Ppm.

Copy for Information Forwarded to (1) Delhi Public School Sarra

(2) N.S.A. Nagar Nigam Kanpur

Nagar Swachh Karkhane
 Alka Singh
 Chemist (K-10)

ALKA SINGH (Chemist)